



Legende		
	Heizung Vorlauf	Kälte Vorlauf
	Heizung Rücklauf	Kälte Rücklauf
	Dampf	Kühlwasser Vorlauf
	Kondensat	Kühlwasser Rücklauf
	Ausblaseleitung	Heiz- / Kühldecke

	KZ-Kantung	Heizleistung
7		83,20 W 95,36 W
8		65,56 W 76,21 W
9		56,16 W 64,36 W
11		27,04 W 38,59 W
12		16,84 W 18,77 W
13		10,44 W 11,93 W
15		79,04 W 90,51 W
16		31,28 W 35,75 W
18		41,68 W 47,61 W
19		52,00 W 59,58 W
20		74,88 W 85,81 W
22		47,84 W 54,82 W
23		24,86 W 28,48 W
24		19,76 W 22,81 W
26		35,76 W 42,24 W


[illegible]

PLANINHALT: GRUNDRISS 1 OG HEIZUNG UND KÄLTE TEIL 1	PLANNR.: HK-P5-BT13-GR-01-1
---	-----------------------------


KREISKLINIKEN ALTÖTTING-BURGHAISEN  
VINZENZ-VON-PAUL-STRASSE 10  
84503 ALTÖTTING

KREISKLINIK ALTOTTING  
ERWEITERUNG UND SANIERUNG 1. BAUABSCHNITT  
NEUBAU NORD/ BT 13

ККАОЕ 



$\pm 0.00 = 398.00$  m dnn

<p>ARCHITEKT</p> <p>FELIX+JONAS ARCHITEKTEN GMBH ICKSTATTSTRASSE 11 a 80469 MÜNCHEN</p>	<p>FACHPLANER</p> <p> <b>Dickert</b> Bauwerk, Innenräume, GmbH DESIGN- UND MANAGEMENT FIRM</p> <p>Reberstraße 44a   93565 SIESEN</p>
---	---

Gruber  
Innenausbau-Holzbau GmbH

